

LICENCE



europa
building
automation
controls
association

Number: **215562**

Corporación Empresarial Altra S.L.

received the licence to use the eu.bac mark for the product

Airzone Central V1.3

for the application(s)

Variable air volume system (without h/c coil)

**based on the certification rules of eu.bac
and the Certificate 210100**

This licence will expire on 17 October 2022



215562

17 October 2016
Brussels

Managing Director Dr. Peter Hug
eu.bac

europa building automation and controls Association - eu.bac
B - 1030 Bruxelles, Boulevard A. Reyers 80



Test Report Summary

Product Information	
Licence Number:	215562
Licensee:	Corporación Empresarial Altra S.L.
Product Identification	Airzone Central V1.3
Test Specifications	
Tested Application:	Variable air volume system (without h/c coil)
Temperature Sensor	
- Type:	NTC 10k AIRZONE
- Time Constant:	0.17 Mins
Actuator Identification	
- Type:	None
Valve Identification	
- Characteristic	None
AV Acronym	
Fan Speed (For Fan Coil Applications)	
- Characteristic	None
Test Result	
Temperature Control Accuracy C_A according EN 15500	Heating - 0.3 K Cooling - 0.3 K

17 October 2016

Brussels

Managing Director Dr. Peter Hug

eu.bac